



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Kids 1st Learning CenterSchool: Kids 1st Learning CenterSampling Date: 6/5/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Kids 1st Learning Center on June 5, 2025. Overall, sixteen (16) outlets were tested resulting in a total of thirty-two (32) samples being sent to the lab.

- Twenty-three (23) samples had no detectable level of lead.
- Nine (9) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-FR-DW1	Front reception area	<1.0	<1.0	N/A
1-1-HALL-DW1	Hallway by workroom	<1.0	<1.0	N/A
1-1-KIT-KF2	3 Compartment Sink - right	<1.0	<1.0	N/A
1-1-4-CF1	4 Year Olds	<1.0	<1.0	N/A
1-1-INF-CF1	Infants - left	<1.0	<1.0	N/A
1-1-TOD-CF2	Toddlers - right	<1.0	<1.0	N/A
1-1-TOD-CF3	Toddlers - middle	<1.0	<1.0	N/A
1-1-3-CF1	3 Year Olds	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-2-CF2	2 Year Olds - right	1.2	<1.0	
1-1-KIT-KF3	Hand Sink - Interior Wall	1.6	<1.0	
1-1-2-CF1	2 Year Olds - left	1.7	<1.0	
1-1-KIT-KF1	3 Compartment Sink - left	1.8	<1.0	
1-1-OUT-OF1	Southside of Building - East	2.4	<1.0	
1-1-INF-CF2	Infants - right	2.7	2.2	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-OUT-OF2	Southside of Building - West	4.0	<1.0	
1-1-TOD-CF1	Toddlers - left	9.6	<1.0	