



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Child Care Center

School: Kinder Castle II

Sampling Date: 6/11/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Child Care Center – Kinder Castle II on June 11, 2025. Overall, four (4) outlets were tested resulting in a total of eight (8) samples being sent to the lab.

- All eight (8) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall Ozark Model water cooler- right of entrance	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet	<1.0	<1.0	N/A
2-1-SCH-WC1	School Aged room- Ozark ice machine	<1.0	<1.0	N/A
2-1-PREK-WC1	Pre-K/2-year-old room Water cooler	<1.0	<1.0	N/A