



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: KCA Center
School: Kiowa Tribe Head Start
Sampling Date: 6/3/2025
Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at KCA Center - Kiowa Tribe Head Start on June 3, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen pot filler	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen sprayer	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen drinking water filler	<1.0	<1.0	N/A
1-1-3YO-CF1	3-year-old room Classroom faucet	<1.0	<1.0	N/A
1-1-3YO-BF1	3-year-old room bathroom faucet	<1.0	<1.0	N/A
1-1-4YO-BF1	4-year-old room bathroom faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-4YO-CF1	4-year-old room Classroom faucet	1.0	<1.0	