



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: KIPP Tulsa College Prep
School: Kipp Tulsa Academy College Prep
Sampling Date: 7/16/2025
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at KIPP Tulsa College Prep - Kipp Tulsa Academy College Prep on July 16, 2025. Overall, fifteen (15) outlets were tested resulting in a total of thirty (30) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Sixteen (16) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC5	8th Grade Hall- Left water cooler	<1.0	<1.0	N/A
1-1-HALL-WC6	8th Grade Hall- Right water cooler	<1.0	<1.0	N/A
1-1-HALL-WC7	5th-6th Grade Hall- left bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC8	5th-6th Grade Hall- right water cooler	<1.0	<1.0	N/A
1-1-KIT-KF5	Kitchen faucet right of 3 compartment sinks	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-HALL-WC2	7th Grade Hall- right water cooler	1.5	1.2	
1-1-HALL-WC1	7th Grade Hall- left water cooler	1.1	1.7	
1-1-KIT-KF2	Kitchen sprayer in 2 compartment sinks	1.8	<1.0	
1-1-HALL-WC4	8th Grade Hall- Bottom water cooler with bottle filler	1.8	1.4	
1-1-HALL-WC3	8th Grade Hall- Top bottle filler	1.2	1.8	
1-1-KIT-KF4	Kitchen sprayer attached to pot filler	1.9	1.9	
1-1-KIT-KF7	Kitchen faucet left in 3 compartment sink	2.5	<1.0	
1-1-KIT-KF1	Kitchen faucet in 2 compartment sink	3.0	<1.0	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-KIT-KF6	Kitchen faucet right in 3 compartment sink	4.0	<1.0	
1-1-KIT-KF3	Kitchen pot filler between 2-3 compartment sink	8.8	2.6	