



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Kreepers and Crawlers Daycare CenterSchool: Kreepers and Crawlers Daycare CenterSampling Date: 6/3/2025Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Kreepers and Crawlers Daycare Center – Kreepers and Crawlers Daycare Center on June 3, 2025. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Twenty (20) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-ENT-DW1	Entrance- water dispenser	<1.0	<1.0	N/A
1-1-GR-BF1	Girls Restroom Left	<1.0	<1.0	N/A
1-1-GR-BF2	Girls Restroom Right	<1.0	<1.0	N/A
1-1-BR-BF1	Boys Restroom Right	<1.0	<1.0	N/A
1-1-BR-BF2	Boys Restroom Left	<1.0	<1.0	N/A
1-1-1YO-CF1	1 year old classroom faucet	<1.0	<1.0	N/A
1-1-2YO-CF1	Corner left 2-year-old classroom faucet	<1.0	<1.0	N/A
1-1-IR-CF1	Infant room classroom faucet (first room to the right)	<1.0	<1.0	N/A
1-1-SAR-CF1	School aged kid room classroom faucet (first space from lobby)	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen double faucet to left of door	<1.0	<1.0	N/A