



OKLAHOMA DRINKING WATER
LEAD TESTING
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Washita Valley Community Action Council

School: Lookeba Head Start

Sampling Date: 6/17/2025

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Washita Valley Community Action Council - Lookeba Head Start on June 17, 2025. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Twelve (12) samples had no detectable level of lead.
- Fourteen (14) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC2	Hall water cooler (closest to girls RR)	<1.0	<1.0	N/A
2-1-CAF-WC2	Cafeteria- water cooler	<1.0	<1.0	N/A
2-1-HALL-WC2	Across main office- water cooler below bottle filler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
2-1-HALL-WC3	Across main office- far right water cooler (closest to women's restroom)	1.2	1.5	
2-1-HALL-WC1	Across main office- bottle filler	2.1	<1.0	
1-1-HALL-WC1	Hall Bottle filler (closest to girls RR)	2.2	<1.0	
1-1-HALL-BF1	Hall between restrooms left of entry FAR LEFT bathroom faucet	2.7	<1.0	
1-1-HALL-BF2	Hall between restrooms left of door MIDDLE bathroom faucet	2.7	<1.0	
2-1-CAF-WC1	Cafeteria- top bottle filler	3.4	<1.0	
2-1-KIT-KF1	Kitchen main pot filler kitchen faucet	3.9	<1.0	
1-1-3-CF1	Classroom faucet in 3 yr old room	4.5	1.7	
1-1-HALL-WC3	Hall left of boy's restroom water cooler	2.1	4.6	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-HALL-BF3	Hall between restrooms left of entry FAR RIGHT bathroom faucet	5.6	1.1	