



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Big Five Community Action

School: Marietta Head Start

Sampling Date: 1/29/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Big Five Community Action - Marietta Head Start on January 29, 2025. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Ten (10) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-LC-CF1	Classroom faucet in left wing classroom	<1.0	<1.0	N/A
1-1-LB-BF1	Bathroom faucet in left wing bathroom	<1.0	<1.0	N/A
1-1-RC-KF1	Kitchen faucet in right wing classroom/building kitchen	<1.0	<1.0	N/A
1-1-RB-BF1	Bathroom faucet in right wing bathroom	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet in classroom kitchen	<1.0	<1.0	N/A