



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Seminole Nation  
 School: Mekusukey Mission Early Head Start  
 Sampling Date: 6/24/2025  
 Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Seminole Nation - Mekusukey Mission Early Head Start on June 24, 2025. Overall, fourteen (14) outlets were tested resulting in a total of twenty-eight (28) samples being sent to the lab.

- Twenty-seven (27) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-KIT1-KF1	Kitchen area - building 1	<1.0	<1.0	N/A
1-1-EHS2-CF1	EHS2 classroom faucet	<1.0	<1.0	N/A
1-1-EHS1-CF1	EHS1 classroom faucet	<1.0	<1.0	N/A
2-1-MR-CF1	Middle room left faucet	<1.0	<1.0	N/A
2-1-MR-CF2	Middle room right faucet	<1.0	<1.0	N/A
2-1-KIT2-KF1	3 bay sink faucet	<1.0	<1.0	N/A
2-1-KIT2-KF2	Sprayer	<1.0	<1.0	N/A
2-1-KIT2-KF3	Faucet right in front of the door	<1.0	<1.0	N/A
2-1-HS3-CF1	Left faucet in 4&5 year old room	<1.0	<1.0	N/A
2-1-HS3-CF2	Right faucet in 4&5 year old room	<1.0	<1.0	N/A
2-1-HS1-CF1	Younger 3 year old room- left faucet	<1.0	<1.0	N/A
2-1-HS1-CF2	Younger 3 year old room- right faucet	<1.0	<1.0	N/A
2-1-EHS3-CF1	Older 2 year old room	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw ( $\mu\text{g/L}$ )	Flush ( $\mu\text{g/L}$ )	Remedial Action
		Initial Sampling		
<b>Low Detection (1.0 - 14.9 <math>\mu\text{g/L}</math>)</b>				
2-1-EHS3-BF1	Older 2 year old room bathroom	<1.0	1.5	