



RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Head Start Centers – Mission to Play on June 10, 2025. Overall, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- All eighteen (18) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet to the far right closest to door	<1.0	<1.0	N/A
1-1-KIT-KF2	Far right kitchen faucet	<1.0	<1.0	N/A
1-1-BATH-BF1	Bathroom between boys' and girls' restroom far right closest to FACP room	<1.0	<1.0	N/A
1-1-BATH-BF2	Bathroom between boys and girl's bathroom far left faucet closet to boys' restroom	<1.0	<1.0	N/A
1-1-HALL-WC1	Hallway Through glass door right of kitchen water dispenser in hallway across from restrooms	<1.0	<1.0	N/A
1-1-BATH-BF3	Bathroom through glass door in hallway far left faucet closet to back wall	<1.0	<1.0	N/A
1-1-BATH-BF4	Bathroom through glass door in hallway far left right faucet	<1.0	<1.0	N/A
1-1-BATH-BF5	Bathroom through glass door in hallway far right left faucet	<1.0	<1.0	N/A
1-1-BATH-BF6	Bathroom through glass door in hallway far right faucet	<1.0	<1.0	N/A