



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Moffett Public School DistrictSchool: Moffett Public School DistrictSampling Dates: 6/26/2025, 8/21/2025Status: Completed Sampling

## RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Moffett Public School District - Moffett Public School District. The initial sampling event occurred on June 26, 2025. The resampling event occurred on August 21, 2025.

In the initial sampling, twenty-eight (28) outlets were tested resulting in a total of fifty-six (56) samples being sent to the lab.

- Fifty-two (52) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-HALL-WC1	Middle school hall- left bottle filler	<1.0	<1.0	N/A		
1-1-HALL-WC2	Middle school hall- left water fountain	<1.0	<1.0	N/A		
1-1-HALL-WC3	Middle school hall- right water fountain	<1.0	<1.0	N/A		
2-1-Pre-K-WC1	Pre-K room- bottle filler	<1.0	<1.0	N/A		
2-1-Pre-K-WC2	Pre-K room- water cooler	<1.0	<1.0	N/A		
2-1-Pre-K-WC3	Pre-K room- bottle filler	<1.0	<1.0	N/A		
2-1-Pre-K-WC4	Pre-K room- water cooler	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
2-1-Pre-K-WC5	Pre-K room- bottle filler	<1.0	<1.0	N/A		
2-1-Pre-K-WC6	Pre-K room- water cooler	<1.0	<1.0	N/A		
3-1-4TH-WC1	4th grade classroom- top bottle filler	<1.0	<1.0	N/A		
3-1-4TH-WC2	4th grade classroom- bottom water fountain	<1.0	<1.0	N/A		
4-1-KB-WC1	Kindergarten building first classroom- top bottle filler	<1.0	<1.0	N/A		
4-1-KB-WC2	Kindergarten building- bottom water fountain	<1.0	<1.0	N/A		
4-1-3RD-WC1	First 3rd grade classroom- top bottle filler	<1.0	<1.0	N/A		
4-1-3RD-WC2	First 3rd grade classroom- bottom water fountain	<1.0	<1.0	N/A		
4-1-3RD2-WC1	Second 3rd grade classroom- top bottle filler	<1.0	<1.0	N/A		
4-1-3RD2-WC2	Second 3rd grade classroom- bottom water fountain	<1.0	<1.0	N/A		
5-1-2ND-WC1	2nd grade building first classroom- top bottle filler	<1.0	<1.0	N/A		
4-1-2ND-WC1	2nd grade building bottom water fountain	<1.0	<1.0	N/A		
6-1-3YR-WC1	3-year-old preschool building- top bottle filler closest to first classroom	<1.0	<1.0	N/A		
6-1-3YR-WC2	3-year-old preschool building- bottom water fountain closest to first classroom	<1.0	<1.0	N/A		
6-1-3YR-WC3	3-year-old preschool building- bottle filler closest to room 2	<1.0	<1.0	N/A		
6-1-3YR-WC4	3-year-old preschool building- bottom fountain closest to classroom 2	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
7-1-KIT-KF1	Kitchen sprayer in 3 compartment sink	<1.0	<1.0	N/A		
7-1-KIT-KF2	Kitchen left side faucet in 3 compartment sink	<1.0	<1.0	N/A		
2-1-1ST-WC1	First grade rooms - top bottle filler	4.0	108.0	Replaced	<1.0	<1.0
<b>Low Detection (1.0 - 14.9 µg/L)</b>						
2-1-1ST-WC2	First grade rooms- bottom water fountain	2.9	2.7	Replaced		