



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

School: Ms. Mandi's Preschool & ELC, Inc.

Sampling Date: 7/9/2025

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Ms. Mandi's Preschool & ELC, Inc. on July 9, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- All fourteen (14) samples had a low detection of lead between 1.0 and 14.9 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen; kitchen faucet	1.3	1.5	
2-1-4S-BF1	Bathroom in Room 4s; bathroom faucet	1.9	1.8	
2-1-4S-CF1	Room 4s; classroom faucet; only faucet	1.9	1.8	
2-1-2S-CF2	Room 2s; classroom faucet; right hand side	1.9	2.0	
2-1-3S-CF1	Room 3s; classroom faucet; left hand side	2.0	1.9	
2-1-3S-CF2	Room 3s; classroom faucet; right hand side	2.0	2.0	
2-1-2S-CF1	Room 2s; classroom faucet; left hand side	2.2	1.9	