



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Mulhall-Orlando Public SchoolsSchool: Mulhall-Orlando Elementary SchoolSampling Date: 5/27/2021Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Mulhall-Orlando Public Schools - Mulhall-Orlando Elementary School on May 27, 2021.

Overall, eighteen (18) outlets were tested resulting in a total of thirty-six (36) samples being sent to the lab.

- Twenty-five (25) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-GYM-WC	Halsey Taylor water cooler in gym; near locker rooms	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen faucet in school kitchen; small sink in front	<1.0	<1.0	N/A
1-1-CON-IM	Manitowoc ice machine in concessions stand	<1.0	<1.0	N/A
1-1-MAIN-WC3	Elkay bottle filler in hallway of main entrance; right side	<1.0	<1.0	N/A
1-1-TL-CF	Classroom faucet in teachers' lounge	<1.0	<1.0	N/A
1-1-TL-WC	Crystal Mountain water cooler in teachers' lounge	<1.0	<1.0	N/A
1-1-KINDER-DW	Drinking water bubbler in kindergarten room; attached to west side classroom faucet	<1.0	<1.0	N/A
1-1-KINDER-CF2	Classroom faucet in kindergarten room; east side	<1.0	<1.0	N/A
1-1-PREK-CF1	Classroom faucet in PreK classroom; east side	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KINDER-CF1	Classroom faucet in kindergarten room; west side	1.0	<1.0	Flush
1-1-KIT-KF1	Kitchen faucet in school kitchen; near dishwasher	1.2	<1.0	Flush
1-1-PREK-CF2	Classroom faucet in PreK classroom; west side	1.4	<1.0	Flush
1-1-KIT-KF2	Kitchen faucet in school kitchen; in back of kitchen	1.6	<1.0	Flush
1-1-HALL-WC2	Halsey Taylor water cooler in hallway near PreK classroom; left side	1.9	<1.0	Flush
1-1-PREK-DW	Drinking water bubbler in PreK classroom; attached to west side classroom faucet	1.9	<1.0	Flush
1-1-CON-KF	Kitchen faucet in concessions stand	2.6	<1.0	Flush
1-1-HALL-WC1	Halsey Taylor water cooler in hallway near PreK classroom; right side	3.0	2.3	Flush
1-1-MAIN-WC1	Elkay water cooler in hallway of main entrance; left side	8.1	2.9	Flush