



LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Muskogee County Head StartSchool: Muskogee County Head Start Main CampusSampling Date: 7/18/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Muskogee County Head Start - Muskogee County Head Start Main Campus on July 18, 2025. Overall, seventeen (17) outlets were tested, leading to thirty-four (34) total samples being sent to the lab.

- Nineteen (19) samples had no detectable level of lead.
- Fifteen (15) samples had a low detection of lead between 1.0 and 14.9 micrograms per Liter (ug/L).
- Zero (0) samples had a high detection of lead equal to or above 15.0 micrograms per Liter (ug/L).

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-LOB-WC1	Lobby; water cooler; water dispenser between girls and boys restrooms	<1.0	<1.0	N/A
1-1-8-CF1	Room 8; classroom faucet; left silver faucet	<1.0	<1.0	N/A
1-1-10-CF2	Room 10; classroom faucet; left white faucet	<1.0	<1.0	N/A
1-1-9-CF2	Room 9; classroom faucet; right white faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-7-CF2	Room 7; classroom faucet; white faucet left of corner	1.2	3.2	
1-1-7-CF1	Room 7; classroom faucet; far right corner silver faucet	1.3	<1.0	
1-1-4-BF1	Bathroom/Room 4; bathroom faucet; far left white faucet in bathroom area	1.3	<1.0	
1-1-10-CF1	Room 10; classroom faucet; right silver faucet	1.3	<1.0	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-4-CF1	Room 4; classroom faucet; far left classroom faucet closest to the door	1.5	<1.0	
1-1-3-CF1	Room 3; classroom faucet; back right classroom faucet	1.5	<1.0	
1-1-3-CF2	Room 3; classroom faucet; left small white faucet in bathroom area	1.5	<1.0	
1-1-9-CF1	Room 9; classroom faucet; left silver faucet	1.7	<1.0	
1-1-8-CF2	Room 8; classroom faucet; right small white faucet	2.0	<1.0	
1-1-7-CF3	Room 7; classroom faucet; far right corner of the room closest to window	2.6	<1.0	
1-1-4-CF2	Room 4; classroom faucet; middle silver faucet	3.2	<1.0	
1-1-KIT-KF2	Kitchen; kitchen faucet; right faucet in 3 compartment sink	3.2	<1.0	
1-1-KIT-KF1	Kitchen; kitchen faucet; left sprayer in 3 compartment sink	8.1	2.5	

Not Sampled				
1-1-9-CF3	Room 9; classroom faucet; far left corner silver faucet	N/A	N/A	