



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Oilton Public Schools

School: Oilton High School

Sampling Date: 7/3/2025

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Oilton Public Schools - Oilton High School on July 3, 2025. Overall, nineteen (19) outlets were tested resulting in a total of thirty-eight (38) samples being sent to the lab.

- Twenty-seven (27) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC2	First hallway left of utility room top right bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC3	First hallway left of utility room- bottom right water cooler	<1.0	<1.0	N/A
1-1-NGYM-WC2	New gym- top bottle filler right water cooler	<1.0	<1.0	N/A
1-1-NGYM-WC3	New gym- bottom right water cooler	<1.0	<1.0	N/A
2-1-HEC-KF1	Home Ec Kitchen faucet	<1.0	<1.0	N/A
3-1-MSHALL-WC1	Middle School Hall LEFT bottle filler near cafeteria	<1.0	<1.0	N/A
3-1-MSHALL-WC2	Middle School Hall Left Water Cooler near cafeteria	<1.0	<1.0	N/A
3-1-CAFÉ-KF1	Middle School Café single compartment faucet	<1.0	<1.0	N/A
3-1-CAFÉ-KF3	Middle School Café 3 compartment faucet back wall	<1.0	<1.0	N/A
4-1-HALL-WC1	Elem Hall Between 109-113 RIGHT Bottle Filler	<1.0	<1.0	N/A
4-1-HALL-WC2	Elem Hall Between 109-113 RIGHT Water Cooler	<1.0	<1.0	N/A
4-1-HALL-WC4	Elem Hall Between 109-113 LEFT Water Cooler	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
5-1-OLDG-IM1	Ice machine in Old Gym	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
5-1-OLDG-WC1	Water cooler in Old Gym	1.2	1.3	
4-1-HALL-WC3	Elem Hall Between 109-113 LEFT Bottle Filler	1.5	<1.0	
3-1-MSHALL-WC3	Middle School Hall Right Water Cooler near cafeteria	2.3	2.6	
1-1-HALL-WC1	First hallway left of utility room LEFT water cooler	4.0	3.4	
2-1-AG-WC1	AG building- water cooler left side wall	6.4	4.5	
1-1-NGYM-WC1	New gym- water cooler left of door	8.6	9.0	
Not Sampled				
3-1-CAFÉ-KF2	Middle School Café Sprayer in 3 compartment sink back wall	Not Sampled	Not Sampled	