



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: UCAP, Inc.School: Okmulgee Head Start & Early Head StartSampling Date: 7/11/2025Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - Okmulgee Head Start & Early Head Start on July 11, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-EHS2-CF1	Classroom faucet; Early Head Start Room 2	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet; main kitchen	<1.0	<1.0	N/A
1-1-HS3-CF1	Classroom faucet; Head Start Room 3	<1.0	<1.0	N/A
1-1-HS2-CF1	Classroom faucet; Head Start Room 2	<1.0	<1.0	N/A
1-1-HS1-CF1	Classroom faucet; Head Start Room 1	<1.0	<1.0	N/A
1-1-EHS1-CF1	Classroom faucet; Early Head Start Room 1	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-EHS2K-KF1	Kitchen faucet; Early Head Start Room 2	1.2	<1.0	