



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: UCAP, Inc.  
School: Pawhuska Head Start #2  
Sampling Date: 8/6/2025  
Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - Pawhuska Head Start #2 on August 6, 2025. Overall, fourteen (14) outlets were tested resulting in a total of twenty-eight (28) samples being sent to the lab.

- Nineteen (19) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Six (6) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-BATH-BF1	Bathroom faucet; bathroom left of front door and office; white faucet	<1.0	<1.0	N/A
1-1-RM1-CF1	Classroom faucet; classroom #1; silver faucet right of room door	<1.0	<1.0	N/A
1-1-RM1-BF1	Bathroom faucet; bathroom in classroom #1; white faucet	<1.0	<1.0	N/A
1-1-BATH-BF2	Bathroom faucet; bathroom in middle classroom; (faucets outside of bathroom no longer in service-broken pipes)	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet; kitchen; left faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet; kitchen; right faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-KIT-WC1	Water cooler; kitchen; water dispenser right of door	<1.0	<1.0	N/A
1-1-RM2-CF1	Classroom faucet; classroom #2; single silver faucet under paper towels dispenser, right of door	<1.0	<1.0	N/A
1-1-RM2-BF1	Bathroom faucet; bathroom in classroom #2	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-RM2-DW1	Drinking water dispenser; classroom #2; silver dispenser outside of bathroom	31.6	1.4	Permanently removed from service
1-1-RM1-DW1	Drinking water dispenser; classroom #1; drinking water faucet; silver dispenser outside of bathroom	73.7	6.0	Permanently removed from service
<b>High Detection (≥15.0 µg/L)</b>				
1-1-KIT-KF3	Kitchen; kitchen faucet; single silver faucet right of door	24.6	<1.0	
1-1-RM1-CF2	Classroom faucet; classroom #1; left white faucet right outside of bathroom	141.0	28.0	
1-1-RM2-CF2	Classroom faucet; classroom #2; left white faucet outside of bathroom	189.0	3.7	