



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: UCAP, Inc.
School: Pawhuska Head Start
Sampling Date: 8/6/2025
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - Pawhuska Head Start on August 6, 2025. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Twenty-two (22) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-BATH-BF1	Bathroom faucet; staff bathroom in main office; single white faucet	<1.0	<1.0	N/A
1-1-LR-WC1	Water cooler; laundry room; dispenser right in front of washing machines	<1.0	<1.0	N/A
1-1-BATH-BF2	Bathroom faucet; bathroom off laundry room; white faucet	<1.0	<1.0	N/A
1-1-GMR-CF1	Classroom faucet; gross motor room; left white faucet	<1.0	<1.0	N/A
1-1-BATH-BF3	Bathroom faucet; main classroom bathroom; bathroom faucet; white faucet	<1.0	<1.0	N/A
1-1-CR-CF1	Classroom faucet; main classroom; left white faucet outside of bathroom	<1.0	<1.0	N/A
1-1-CR-DW1	Drinking water dispenser; main classroom; drinking water faucet	<1.0	<1.0	N/A
1-1-BATH-BF4	Bathroom faucet; bathroom in storage/meeting room; white faucet	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet; kitchen; far left faucet in 1 compartment sink, attached sprayer not working	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet; kitchen; far left faucet in 3 compartment sink	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF3	Kitchen faucet; kitchen; far right faucet in 3 compartment sink	1.0	<1.0	
1-1-GMR-DW1	Drinking water dispenser; gross motor room; silver faucet outside of bathroom	1.2	<1.0	
1-1-GMR-BF1	Bathroom faucet; bathroom in gross motor room	4.1	3.4	