

District: Community Action Agency of OKC

School: Plainview Head Start

Sampling Dates: 8/20/2024, 7/31/2025

Status: Completed Sampling

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of OKC – Plainview Head Start. The initial sampling event occurred on August 20, 2024. The resampling event occurred on July 31, 2025.

In the initial sampling, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- One (1) sample had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-AB-BF1	Bathroom faucet in bathroom off Classroom A; right side	<1.0	<1.0	N/A		
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A		
1-1-A-WC1	Elkay water cooler in Classroom A	<1.0	<1.0	N/A		
1-1-HALL-WC1	Elkay water cooler in main hallway	<1.0	<1.0	N/A		
1-1-B-WC1	Elkay water cooler in Classroom B	<1.0	<1.0	N/A		
1-1-BB-BF1	Bathroom faucet in bathroom off Classroom B	<1.0	<1.0	N/A		
Low Detection (1.0 - 14.9 µg/L)						

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-AB-BF2	Bathroom faucet in bathroom off Classroom A; left side	1.1	<1.0		1.1	<1.0