



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Home Childcare CenterSchool: Robinson, KatrinaSampling Date: 6/13/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Home Childcare Center - Robinson, Katrina on June 13, 2025. Overall, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Nine (9) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Three (3) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-TOD-WC1	Left water cooler in Toddler room	<1.0	<1.0	N/A
1-1-TOD-WC2	Right water cooler in Toddler room	<1.0	<1.0	N/A
1-1-TOD-BF1	Bathroom faucet in toddlers' area- next to kitchen	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-2-BF1	Bathroom faucet in twos room	1.8	<1.0	
1-1-HALL-BF1	Hallway bathroom faucet	2.2	<1.0	
1-1-IN-CF1	faucet in infant room	11.6	6.7	
High Detection (≥15.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet - previously turned off, problem with tank	15.1	<1.0	
1-1-2IN-CF1	Second Infant room classroom faucet - next to kitchen, previously turned off due to tank problems	47.3	41.5	