



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: UCAP, Inc.  
School: SCUS Head Start Panama  
Sampling Date: 6/27/2025  
Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - SCUS Head Start Panama on June 27, 2025. Overall, three (3) outlets were tested resulting in a total of six (6) samples being sent to the lab.

- One (1) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-RM2-BF1	Room 2/Bathroom; Bathroom faucet	1.1	<1.0	Handwash Only
1-1-RM1-BF1	Head Start Room 1; Bathroom faucet; Faucet in front of door	1.6	1.1	Handwash Only
1-1-RM1-CF1	Head Start Room 1; Classroom faucet; Faucet on back wall	2.2	2.8	Added Filter