



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: UCAP, Inc.
School: SCUS Head Start Spiro
Sampling Date: 6/27/2025
Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - SCUS Head Start Spiro on June 27, 2025. Overall, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Ten (10) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-RM1-CF2	Room 1; Classroom faucet; Right faucet right of door	<1.0	<1.0	N/A
1-1-RM2-CF2	Room 2; Classroom faucet; Right faucet right of door	<1.0	<1.0	N/A
1-1-KIT-KIT1	Kitchen; Kitchen faucet in 2 compartment sink	<1.0	<1.0	N/A
1-1-EHS-CF2	Early Head Start Room; Classroom faucet; Right faucet left of kitchen	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-RM1-CF1	Room 1; Classroom faucet; Left faucet right of door	1.6	1.4	Handwash Only
1-1-EHS-CF1	Early Head Start Room; Classroom faucet; Left faucet left of kitchen	2.2	<1.0	Handwash Only
1-1-RM2-CF1	Room 2; Classroom faucet; Left faucet right of door	5.0	4.7	Handwash Only
1-1-EHS-CF3	Early Head Start Room; Classroom faucet; Single faucet right of kitchen	13.0	<1.0	Removed