



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: SCUS Head Start

School: Talihina

Sampling Date: 7/22/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at SCUS Head Start – Talihina on July 22, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HS-CF1	Head Start room- left faucet outside of bathroom	<1.0	<1.0	N/A
1-1-HS-CF2	Head Start room- right faucet outside of bathroom	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen- left side faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen- right side faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-EHS-CF1	Early Head Start- left side faucet outside of bathroom	<1.0	<1.0	N/A
1-1-EHS-CF2	Early Head Start- right side faucet outside of bathroom	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen- single compartment sink left of 3 compartment	<1.0	1.9	