



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Bright HorizonsSchool: Saint Francis Child Development CenterSampling Date: 7/17/2025Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Bright Horizons – Saint Francis Child Development Center on July 17, 2025. Overall, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KPREP-WC1	K-Prep water cooler right of door	<1.0	<1.0	N/A
1-1-PRE-CF1	Pre-K back right wall classroom faucet	<1.0	<1.0	N/A
1-1-TOD-CF1	Toddlers' classroom faucet front wall	<1.0	<1.0	N/A
1-1-2S-CF1	Twos room classroom faucet wall of the door	<1.0	<1.0	N/A
1-1-KIT-IM1	Kitchen ice machine	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen right side faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen 2 compartment faucet	<1.0	1.3	
1-1-HALL-WC1	Hall between 2's room and toddler room-right water cooler	1.6	<1.0	