



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Childcare Center  
School: Scribbles & Giggles  
Sampling Date: 6/24/2025  
Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Head Start Center - Scribbles & Giggles on June 24, 2025. Overall, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- Zero (0) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF 1	Kitchen faucet	1.9	4.7	