



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Muskogee County Head StartSchool: Shawnee Early Head StartSampling Date: 7/18/2025Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Muskogee County Head Start - Shawnee Early Head Start on July 18, 2025. Overall, eighteen (18) outlets were tested resulting in a total of thirty-six (36) samples being sent to the lab.

- Twenty-eight (28) samples had no detectable level of lead.
- Eight (8) samples had a low detection of lead between 1.0 and 14.9 micrograms per Liter (ug/L).
- Zero (0) samples had a high detection of lead equal to or above 15.0 micrograms per Liter (ug/L).

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall; water cooler; bottle filler right of front door	<1.0	<1.0	N/A
1-1-RM3-BF1	Bathroom in Classroom 3; bathroom faucet	<1.0	<1.0	N/A
1-1-RM4-BF1	Bathroom in Classroom 4; bathroom faucet	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen; kitchen faucet; faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-RM2-CF1	Classroom 2; classroom faucet left of door	<1.0	<1.0	N/A
1-1-RM2-BF1	Bathroom in Classroom 2; bathroom faucet; right white faucet	<1.0	<1.0	N/A
1-1-RM1-CF1	Classroom 1; classroom faucet right of door	<1.0	<1.0	N/A
1-1-RM1-CF2	Classroom 1; classroom faucet; small white faucet right of door	<1.0	<1.0	N/A
1-1-RM1-BF1	Bathroom in Classroom 1; bathroom faucet	<1.0	<1.0	N/A
1-1-RM2-CF3	Classroom 2; classroom faucet; small white faucet next to door	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-RM4-CF2	Classroom 4; classroom faucet; small white faucet right of silver faucet closest to door	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-RM4-CF1	Classroom 4; classroom faucet left of door	1.2	<1.0	
1-1-RM2-CF2	Classroom 2; classroom faucet; middle faucet in bathroom area	1.4	<1.0	
1-1-LOB-BF1	Lobby in Girls Restroom; bathroom faucet	1.5	<1.0	
1-1-RM3-CF1	Classroom 3; classroom faucet next to door	1.6	<1.0	
1-1-RM3-CF2	Classroom 3; classroom faucet; small white faucet next to door	2.0	<1.0	
1-1-RM1-CF3	Classroom 1; classroom faucet; faucet left of door in bathroom area	2.2	<1.0	
1-1-LOB-BF2	Lobby in Boys Restroom; bathroom faucet	13.1	2.0	