



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Home Childcare Center

School: Simon, Dominique

Sampling Date: 7/15/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Home Childcare Center – Simon, Dominique on July 15, 2025. Overall, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- All two (2) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF	Kitchen faucet in kitchen	<1.0	<1.0	N/A