



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Sunbeam Family Services  
 School: Educare OKC  
 Sampling Date: 8/14/2024  
 Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Educare OKC on August 14, 2024. Overall, seventy-two (72) outlets were tested resulting in a total of one hundred forty-four (144) samples being sent to the lab.

- One hundred twenty-four (124) samples had no detectable level of lead.
- Twenty (20) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-TL-KF1	Kitchen faucet in teachers' lounge	<1.0	<1.0	N/A
1-1-TL-IM1	Scotsman ice machine in teachers' lounge	<1.0	<1.0	N/A
1-1-TL-DW1	Drinking water dispenser attached to ice machine in teachers' lounge	<1.0	<1.0	N/A
1-1-124-CF1	Classroom faucet in Room 124; tall sink to right	<1.0	<1.0	N/A
1-1-124B-BF1	Bathroom faucet in bathroom between Rooms 124 and 126; left side	<1.0	<1.0	N/A
1-1-126-CF1	Classroom faucet in Room 126; tall sink to left	<1.0	<1.0	N/A
1-1-126-CF2	Classroom faucet in Room 126; tall sink to right	<1.0	<1.0	N/A
1-1-137-CF1	Classroom faucet in Room 137; tall sink	<1.0	<1.0	N/A
1-1-137-CF2	Classroom faucet in Room 137; small sink to left	<1.0	<1.0	N/A
1-1-137B-BF2	Bathroom faucet in bathroom between Rooms 137 and 139; right side	<1.0	<1.0	N/A
1-1-139-CF1	Classroom faucet in Room 139; tall sink	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-139-CF2	Classroom faucet in Room 139; small sink to right	<1.0	<1.0	N/A
1-1-122-CF2	Classroom faucet in Room 122; tall sink to left	<1.0	<1.0	N/A
1-1-122-CF3	Classroom faucet in Room 122; short sink	<1.0	<1.0	N/A
1-1-131-CF1	Classroom faucet in Room 131; tall sink to left	<1.0	<1.0	N/A
1-1-131-CF2	Classroom faucet in Room 131; tall sink to right	<1.0	<1.0	N/A
1-1-131-CF3	Classroom faucet in Room 131; small sink	<1.0	<1.0	N/A
1-1-135-CF1	Classroom faucet in Room 135; tall sink	<1.0	<1.0	N/A
1-1-135-CF2	Classroom faucet in Room 135; small sink to left	<1.0	<1.0	N/A
1-1-135-CF3	Classroom faucet in Room 135; small sink to right	<1.0	<1.0	N/A
1-1-135B-BF1	Bathroom faucet in bathroom between Rooms 135 and 144; left side	<1.0	<1.0	N/A
1-1-135B-BF2	Bathroom faucet in bathroom between Rooms 135 and 144; right side	<1.0	<1.0	N/A
1-1-144-CF1	Classroom faucet in Room 144; tall sink	<1.0	<1.0	N/A
1-1-144-CF2	Classroom faucet in Room 144; small sink to right	<1.0	<1.0	N/A
1-1-HALL-WC1	Elkay water cooler outside kitchen; right side	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay water cooler outside kitchen; left side	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet at entrance to kitchen; on left side	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen faucet at prep station in kitchen; in back of room	<1.0	<1.0	N/A
1-1-167-CF1	Classroom faucet in Room 167; tall sink to right	<1.0	<1.0	N/A
1-1-167-CF2	Classroom faucet in Room 167; tall sink to left	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-167-CF3	Classroom faucet in Room 167; short sink	<1.0	<1.0	N/A
1-1-167B-BF2	Bathroom faucet in bathroom between Rooms 167 and 158; right side	<1.0	<1.0	N/A
1-1-158-CF1	Classroom faucet in Room 158; tall sink to left	<1.0	<1.0	N/A
1-1-158-CF2	Classroom faucet in Room 158; tall sink to right	<1.0	<1.0	N/A
1-1-158-CF3	Classroom faucet in Room 158; small sink	<1.0	<1.0	N/A
1-1-154-CF1	Classroom faucet in Room 154; tall sink	<1.0	<1.0	N/A
1-1-154-CF2	Classroom faucet in Room 154; small sink to left	<1.0	<1.0	N/A
1-1-154-CF3	Classroom faucet in Room 154; small sink to right	<1.0	<1.0	N/A
1-1-154B-BF1	Bathroom faucet in bathroom between Rooms 154 and 145; left side	<1.0	<1.0	N/A
1-1-154B-BF2	Bathroom faucet in bathroom between Rooms 154 and 145; right side	<1.0	<1.0	N/A
1-1-145-CF1	Classroom faucet in Room 145; tall sink	<1.0	<1.0	N/A
1-1-162-CF2	Classroom faucet in Room 162; tall sink to left	<1.0	<1.0	N/A
1-1-162-CF3	Classroom faucet in Room 162; short sink	<1.0	<1.0	N/A
1-1-162B-BF1	Bathroom faucet in bathroom between Rooms 162 and 160; left side	<1.0	<1.0	N/A
1-1-160-CF1	Classroom faucet in Room 160; tall sink to left	<1.0	<1.0	N/A
1-1-160-CF2	Classroom faucet in Room 160; tall sink to right	<1.0	<1.0	N/A
1-1-160-CF3	Classroom faucet in Room 160; small sink	<1.0	<1.0	N/A
1-1-152-CF1	Classroom faucet in Room 152; tall sink	<1.0	<1.0	N/A
1-1-152-CF3	Classroom faucet in Room 152; small sink to right	<1.0	<1.0	N/A
1-1-152B-BF1	Bathroom faucet in bathroom between Rooms 152 and 150; left side	<1.0	<1.0	N/A

Sample ID	Comments	First Draw ( $\mu\text{g/L}$ )	Flush ( $\mu\text{g/L}$ )	Remedial Action
		Initial Sampling		
1-1-152B-BF2	Bathroom faucet in bathroom between Rooms 152 and 150; right side	<1.0	<1.0	N/A
1-1-150-CF1	Classroom faucet in Room 150; tall sink	<1.0	<1.0	N/A
1-1-150-CF3	Classroom faucet in Room 150; small sink to left	<1.0	<1.0	N/A
1-1-126-CF3	Classroom faucet in Room 126; small sink	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 <math>\mu\text{g/L}</math>)</b>				
1-1-124-CF3	Classroom faucet in Room 124; short sink	1.0	<1.0	
1-1-145-CF3	Classroom faucet in Room 145; small sink to left	1.0	<1.0	
1-1-122-CF1	Classroom faucet in Room 122; tall sink to right	1.1	<1.0	
1-1-124-CF2	Classroom faucet in Room 124; tall sink to left	1.2	<1.0	
1-1-122B-BF1	Bathroom faucet in bathroom between Rooms 122 and 131; left side	1.2	<1.0	
1-1-144-CF3	Classroom faucet in Room 144; small sink to left	1.3	<1.0	
1-1-KIT-KF2	Kitchen faucet near stove in kitchen	1.4	<1.0	
1-1-162-CF1	Classroom faucet in Room 162; tall sink to right	<1.0	1.8	
1-1-137B-BF1	Bathroom faucet in bathroom between Rooms 137 and 139; left side	1.8	<1.0	
1-1-167B-BF1	Bathroom faucet in bathroom between Rooms 167 and 158; left side	1.9	<1.0	
1-1-162B-BF2	Bathroom faucet in bathroom between Rooms 162 and 160; right side	1.9	<1.0	
1-1-150-CF2	Classroom faucet in Room 150; small sink to right	2.7	<1.0	
1-1-137-CF3	Classroom faucet in Room 137; small sink to right	2.9	<1.0	
1-1-124B-BF2	Bathroom faucet in bathroom between Rooms 124 and 126; right side	2.9	1.5	
1-1-139-CF3	Classroom faucet in Room 139; small sink to left	3.6	<1.0	

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-152-CF2	Classroom faucet in Room 152; small sink to left	5.7	<1.0	
1-1-122B-BF2	Bathroom faucet in bathroom between Rooms 122 and 131; right side	<1.0	7.7	
1-1-105-KF1	Kitchen faucet in meeting room (Room 105)	11.1	1.2	