



OKLAHOMA DRINKING WATER

**LEAD TESTING**

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Sunbeam Family ServicesSchool: Wovenlife Child Development ProgramSampling Date: 12/7/2021Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Wovenlife Child Development Program on December 7, 2021. Overall, forty-three (43) outlets were tested resulting in a total of eighty-six (86) samples being sent to the lab.

- Seventy-two (72) samples had no detectable level of lead.
- Fourteen (14) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-EHS6-BF	Bathroom faucet in Early HeadStart Room 6 bathroom	<1.0	<1.0	N/A
1-1-EHS5-BF	Bathroom faucet in Early HeadStart Room 5 bathroom	<1.0	<1.0	N/A
1-1-EHS5-CF1	Classroom faucet of handwash sink in Early HeadStart Room 5	<1.0	<1.0	N/A
1-1-EHS5-CF2	Classroom faucet of cleaning sink in Early HeadStart Room 5	<1.0	<1.0	N/A
1-1-EHS1-CF	Classroom faucet of cleaning sink in Early HeadStart Room 1	<1.0	<1.0	N/A
1-1-EHS4-CF1	Classroom faucet of handwash sink in Early HeadStart Room 4	<1.0	<1.0	N/A
1-1-EHS4-CF2	Classroom faucet of cleaning sink in Early HeadStart Room 4	<1.0	<1.0	N/A
1-1-EHS4-BF1	Bathroom faucet in Early HeadStart Room 4 bathroom; left side	<1.0	<1.0	N/A
1-1-EHS4-BF2	Bathroom faucet in Early HeadStart Room 4 bathroom; right side	<1.0	<1.0	N/A
1-1-EHS3-CF1	Classroom faucet of handwash sink in Early HeadStart Room 3	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-EHS2-CF1	Classroom faucet of handwash sink in Early HeadStart Room 2	<1.0	<1.0	N/A
1-1-EHS2-CF2	Classroom faucet of cleaning sink in Early HeadStart Room 2	<1.0	<1.0	N/A
1-1-EHS2-BF	Bathroom faucet in Early HeadStart Room 2 bathroom	<1.0	<1.0	N/A
1-1-SENS-CF1	Classroom faucet of handwash sink in Sensory Room	<1.0	<1.0	N/A
1-1-SENS-BF	Bathroom faucet in Sensory Room bathroom	<1.0	<1.0	N/A
1-1-TODD-CF1	Classroom faucet of handwash sink in Toddler Room	<1.0	<1.0	N/A
1-1-INF1-CF1	Classroom faucet of handwash sink in Infant Room 1	<1.0	<1.0	N/A
1-1-INF1-CF2	Classroom faucet of cleaning sink in Infant Room 1	<1.0	<1.0	N/A
1-1-INF2-CF1	Classroom faucet of handwash sink in Infant Room 2	<1.0	<1.0	N/A
1-1-INF2-CF2	Classroom faucet of cleaning sink in Infant Room 2	<1.0	<1.0	N/A
1-1-RM3-CF	Classroom faucet of handwash sink in Room 3	<1.0	<1.0	N/A
1-1-RM2-CF	Classroom faucet of handwash sink in Room 2	<1.0	<1.0	N/A
1-1-RM2-BF1	Bathroom faucet in Room 2 bathroom; left side	<1.0	<1.0	N/A
1-1-RM2-BF2	Bathroom faucet in Room 2 bathroom; middle sink	<1.0	<1.0	N/A
1-1-RM2-BF3	Bathroom faucet in Room 2 bathroom; right side	<1.0	<1.0	N/A
1-1-RM1-CF	Classroom faucet of handwash sink in Room 1	<1.0	<1.0	N/A
1-1-RM1-BF1	Bathroom faucet in Room 1 bathroom; left side	<1.0	<1.0	N/A
1-1-RM1-BF2	Bathroom faucet in Room 1 bathroom; right side	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-HALL-WC	Halsey Taylor water cooler near main entrance in lobby	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-NEWKIT-KF	Kitchen faucet in new school kitchen; was not fully renovated at time of sampling and was used as storage	1.1	<1.0	
1-1-ADKIT-KF2	Kitchen faucet in adult kitchen; cleaning sink	1.1	<1.0	
1-1-EHS3-CF2	Classroom faucet of cleaning sink in Early HeadStart Room 3	1.2	<1.0	
1-1-TODD-CF2	Classroom faucet of cleaning sink in Toddler Room	1.2	<1.0	
1-1-TODD-BF	Bathroom faucet in Toddler Room bathroom	1.2	<1.0	
1-1-EHS6-CF1	Classroom faucet of handwash sink in Early HeadStart Room 6	1.3	<1.0	
1-1-ADKIT-KF1	Kitchen faucet in adult kitchen; handwash sink	1.3	<1.0	
1-1-GRT-CF	Classroom faucet in Sink of Great Room	1.4	<1.0	
1-1-SENS-CF2	Classroom faucet of cleaning sink in Sensory Room	1.9	<1.0	
1-1-EHS1-BF	Bathroom faucet in Early HeadStart Room 1 bathroom	2.0	<1.0	
1-1-LIB-CF2	Classroom faucet of cleaning sink in Library	2.9	<1.0	
1-1-THRPY-CF	Classroom faucet in sink of Therapy Room	3.5	<1.0	
1-1-LIB-CF1	Classroom faucet of handwash sink in Library	3.6	<1.0	
1-1-EHS6-CF2	Classroom faucet of cleaning sink in Early HeadStart Room 6	4.3	<1.0	