



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Anadarko Public SchoolSchool: Sunset Elementary SchoolSampling Date: 6/6/2025Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Anadarko Public School – Sunset Elementary School on June 6, 2025. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Eighteen (18) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-ENT-WC1	Entrance hallway- left water cooler	<1.0	<1.0	N/A
1-1-ENT-WC2	Entrance hallway- right water cooler	<1.0	<1.0	N/A
1-1-CAF-IM1	Cafeteria ice machine	<1.0	<1.0	N/A
1-1-HALL-WC1	Hall between conference room and room 16- far right water cooler	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall between conference room and room 16- far left water cooler	<1.0	<1.0	N/A
1-1-HALL-BF1	Hall between janitor room and room 22 - bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC3	Hall between janitor room and room 22 - water cooler under bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC4	Hall between janitor room and room 22 - far left water cooler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-HALL-WC5	Hall left of rom 9- far right water cooler	<1.0	1.3	
1-1-KIT-KF2	Kitchen second pot filler	1.7	<1.0	