



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: NACT Head Start

School: Tisdale Campus

Sampling Date: 7/9/2025

Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at NACT Head Start – Tisdale Campus on July 9, 2025. Overall, fourteen (14) outlets were tested resulting in a total of twenty-eight (28) samples being sent to the lab.

- Twenty-five (25) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall (110) LEFT water cooler	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall (110) RIGHT Bottle Filler	<1.0	<1.0	N/A
1-1-HALL-WC3	Hall (110) RIGHT Water Cooler	<1.0	<1.0	N/A
1-1-CAFÉ-WC1	Cafeteria- LEFT Water Cooler	<1.0	<1.0	N/A
1-1-CAFÉ-WC2	Cafeteria- RIGHT Water Cooler	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in 2 compartment sink	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen Sprayer attached to 2 compartment sink	<1.0	<1.0	N/A
1-1-KIT-IM1	Kitchen Ice Machine	<1.0	<1.0	N/A
1-1-HALL-WC4	Hall (107b) LEFT water cooler	<1.0	<1.0	N/A
1-1-HALL-WC5	Hall (107b) RIGHT BOTTLE FILLER	<1.0	<1.0	N/A
1-1-HALL-WC6	Hall (107b) LEFT Water Cooler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF4	Kitchen single compartment in the middle row	<1.0	1.0	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-KIT-KF1	Kitchen far right single compartment faucet	1.4	<1.0	
1-1-KIT-KF5	Kitchen far left single faucet next to ice machine	1.9	<1.0	