



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Tuskahoma Public SchoolSchool: Tuskahoma Public SchoolSampling Date: 7/22/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tuskahoma Public School - Tuskahoma Public School on July 22, 2025. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Eighteen (18) samples had no detectable level of lead.
- Eight (8) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Not Sampled | | | | |
|--------------|--|-------------|-------------|--|
| 3-1-CAFÉ-WC1 | Water cooler; in cafeteria; bottle filler (connected water cooler does not work) | Not Sampled | Not Sampled | |

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|------------------------|--|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Non-Detect (<1.0 µg/L) | | | | |
| 1-1-NUR-CF1 | Classroom faucet; 1 st building; 1st nursery room closest to back door; faucet on left wall | <1.0 | <1.0 | N/A |
| 1-1-DR-CF1 | Classroom faucet; 1 st building; daycare room; faucet on right wall | <1.0 | <1.0 | N/A |
| 2-1-GYM-WC1 | Water cooler; 2 nd building; gymnasium; water dispenser on left side of basketball area | <1.0 | <1.0 | N/A |
| 2-1-GYM-WC2 | Water cooler; 2 nd building; gymnasium; water dispenser on right side in basketball area | <1.0 | <1.0 | N/A |
| 2-1-CON-KF1 | Kitchen faucet; 2 nd building; concessions stand; faucet in 2 compartment sink | <1.0 | <1.0 | N/A |

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|--|--|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| 2-1-CON-KF2 | Kitchen faucet; 2 nd building; concessions stand; sprayer in 2 compartment sink | <1.0 | <1.0 | N/A |
| 1-1-KIT-KF1 | Kitchen faucet; 1 st building; Kitchen in cafeteria; sprayer right side of 3 compartment sink | <1.0 | <1.0 | N/A |
| 3-1-KIT-KF1 | Kitchen faucet; 3 rd building; cafeteria; faucet ride side of 3 compartment sink | <1.0 | <1.0 | N/A |
| Low Detection (1.0 - 14.9 µg/L) | | | | |
| 1-1-HALL-WC2 | Water cooler; 1 st building; hallway across from room 3; on right side | 1.7 | 1.7 | |
| 3-1-KIT-IM1 | Kitchen faucet; 3 rd building; kitchen in cafeteria; right corner next to double door fridge | <1.0 | 2.0 | |
| 1-1-HALL-WC1 | Water cooler; 1 st building; hallway across from room 3; on left side | 2.0 | <1.0 | |
| 3-1-KIT-KF3 | Kitchen faucet; 3 rd building; kitchen in cafeteria; faucet left side of 3 compartment sink | 3.1 | 1.3 | |
| 3-1-KIT-KF2 | Kitchen faucet; 3 rd building; kitchen in cafeteria; sprayer left side of 3 compartment sink | 3.3 | 1.5 | |