



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of Oklahoma CitySchool: Valley Brook Head StartSampling Dates: 9/21/2024, 7/15/2025Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City – Valley Brook Head Start. The initial sampling event occurred on September 21, 2024. The resampling event occurred on July 15, 2025.

In the initial sampling, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Fifteen (15) samples had no detectable level of lead.
- Seven (7) samples had a low detection of lead between 1.0 and 14.9 micrograms per Liter (ug/L).
- Zero (0) samples had a high detection of lead equal to or above 15.0 micrograms per Liter (ug/L).

In the resampling, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Five (5) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-HALL-WC1	Elkay water cooler in main hallway	<1.0	<1.0	N/A		
1-1-GR-BF1	Bathroom faucet in girls' restroom; left sink	<1.0	<1.0	N/A		
1-1-BR-BF1	Bathroom faucet in boys' restroom; left sink	<1.0	<1.0	N/A		
1-1-A-CF1	Classroom faucet in Rm A	<1.0	<1.0	N/A		
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A		
1-1-KIT-IM1	Ice machine in facility kitchen	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-GR-BF2	Bathroom faucet in girls' restroom; right sink	<1.0	1.0		<1.0	<1.0
Low Detection (1.0 - 14.9 µg/L)						
1-1-BR-BF2	Bathroom faucet in boys' restroom; right sink	1.0	1.9		1.3	1.1
1-1-C-CF1	Classroom faucet in Rm C	1.8	<1.0		1.3	<1.0
1-1-B-CF1	Classroom faucet in Rm B	2.0	<1.0		2.9	<1.0
1-1-TL-CF1	Classroom faucet in teachers' lounge	6.1	1.5		5.2	<1.0