



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: INCA Community Services

School: Wapanucka Head Start

Sampling Dates: 5/3/2024, 7/24/2025

Status: Complete

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at INCA Community Services - Wapanucka Head Start. The initial sampling event occurred on May 3, 2024. The resampling event occurred on July 24, 2025.

In the initial sampling, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- All two (2) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-HALL-WC2	Elkay water cooler with bottle filler in hallway to Wapanucka 1 classroom; right side	<1.0	<1.0			
1-1-HALL-WC3	Elkay bottle filler in hallway to Wapanucka 1 classroom; right side	<1.0	<1.0			
1-1-HALL-BF	Bathroom faucet in hallway to Wapanucka 1 classroom	<1.0	<1.0			
1-1-WAP1-CF	Classroom faucet in Wapanucka 1 classroom; on wall next to bathroom	<2.0*	<1.0			
1-1-WAP1-BF	Bathroom faucet in Wapanucka 1 bathroom	<2.0*	<2.0*			
1-1-WAP2-BF	Bathroom faucet in Wapanucka 2 bathroom	<2.0*	<4.0*			

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-WAP2-CF	Classroom faucet in Wapanucka 2; next to bathroom	1.1	<4.0*		<1.0	<1.0
Not Sampled						
1-1-HALL-WC1	Elkay water cooler in hallway to Wapanucka 1 classroom; left side					

*Samples underwent a different testing procedure, changing the reporting value