



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of Oklahoma City

School: Will Rogers Head Start

Sampling Dates: 8/21/2024, 7/15/2025

Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City – Will Rogers Head Start. The initial sampling event occurred on August 21, 2024. The resampling event occurred on July 15, 2025.

In the initial sampling, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Seventeen (17) samples had no detectable level of lead.
- Seven (7) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Two (2) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, eight (8) outlets were tested resulting in a total of sixteen samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Ten (10) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Four (4) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A		
1-1-CAF-IM1	Manitowoc ice machine in cafeteria	<1.0	<1.0	N/A		
1-1-TR-CF1	Classroom faucet in training room	<1.0	<1.0	N/A		
1-1-TRB-BF1	Bathroom faucet in training room restroom; had been out of order	<1.0	<1.0	N/A		
1-1-BR-BF1	Bathroom faucet in boys' restroom	<1.0	<1.0	N/A		
1-1-CAFR-BF1	Bathroom faucet in cafeteria restroom	1.0	<1.0		<1.0	<1.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Low Detection (1.0 - 14.9 µg/L)						
1-1-HALL-WC1	Elkay water cooler in main hallway near entrance	<1.0	1.3		1.1	1.3
1-1-1-CF1	Classroom faucet in Classroom 1	2.0	<1.0		1.5	1.0
1-1-2-CF1	Classroom faucet in Classroom 2	55.4	<1.0		1.7	7.9
High Detection (≥15.0 µg/L)						
1-1-DO-CF1	Classroom faucet in director's office	3.5	3.0		16.0	4.7
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	1.2	<1.0		56.6	3.3
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	15.1	<1.0		82.3	2.1
1-1-3-CF1	Classroom faucet in Classroom 3	1.3	<1.0		131.0	1.4