



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Home Childcare Center

School: Wilson, Stephanie

Sampling Date: 7/22/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Home Childcare Center - Wilson, Stephanie on July 22, 2025. Overall, two (2) outlets were tested resulting in a total of four (4) samples being sent to the lab.

- All four (4) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF	Kitchen faucet in kitchen	<1.0	<1.0	N/A
1-1-BR-BF	Bathroom near living room- bathroom faucet	<1.0	<1.0	N/A