

---

# Safety-Gram

## Title 45, Chapter 11

---

SEPTEMBER 2011

Volume 12, Number 9

# FLAMMABLE STORAGE AREA

### SECTION 910.B.3

Areas surrounding flammable-liquid storage tanks and electric

substations and transformers shall be kept free from

dry grass, weeds, underbrush and other combustible materials for at least (25) feet in all directions.



---

# KEEP IT CLEAN