



**OKLAHOMA CORPORATION COMMISSION  
PETROLEUM STORAGE TANK DIVISION  
(405) 521-4683 FAX: (405) 521-4945**

**SUMMARY OF SIGNIFICANT RULE CHANGES  
EFFECTIVE OCTOBER 1, 2020**

[OAC 65:15-13-1] If you sell E15 fuel, the tank must have "E15" in black with a black border around lid. Use the same colors that you currently use for unleaded fuel, 86 through 91 octane, for the lid.

[OAC 165:15-15-35(e)] The price per gallon that is charged at the dispenser must be the same price that is advertised on the facility's marquee and/or remote billboards. The price per gallon that is advertised on the facility's marquee and/or remote billboards must be the same price that is charged at the dispenser.

[OAC 165:25-1-41] PSTD requires owners and operators use the online PST Portal for reporting and scheduling tank activities such as installations, closures, and testing. The online portal is also used for submitting registrations, change in ownership, change of mailing address or tank status, switching to a different method of release detection, when a tank is taken temporarily out of use, returned to service, or permanently closed, and when switching substances that are greater than 10% ethanol or 20% biodiesel. The online portal can be found at <https://apps.occeweb.com/pstportal> or the link is located on PSTD's webpage on the Commission's website, [www.occeweb.com](http://www.occeweb.com). Required release detection forms can be found on the link for Compliance Forms.

[OAC 165:25-2-55.2(d)] Vent risers must be located or protected and anchored, to prevent damage from traffic, wind, or testing procedures. Vapors could ignite and possibly cause an explosion so protecting them from damage is important for public safety.

[OAC 165:25-3-6.25(b)] On new installations, the containment sumps used for interstitial monitoring of piping must be tested at installation using a PSTD-approved testing method that tests the sump above the highest penetration or sump sidewall seam must be used. After initial testing, sumps must be tested every 3 years or you can use double-walled containment sumps with periodic interstitial monitoring every 30 days. Records demonstrating compliance must be maintained for 3 years.

**If you have questions or need additional information  
Contact the PSTD Compliance Department at (405) 521-4683**

**RELEASES OR SUSPECTED RELEASES MUST BE REPORTED TO PSTD WITHIN 24 HOURS  
RELEASES REQUIRING EMERGENCY CORRECTIVE ACTION MUST BE REPORTED IMMEDIATELY TO**

**[PSTReleaseReporting@occ.ok.gov](mailto:PSTReleaseReporting@occ.ok.gov)**

**OR BY PHONE AT (405) 521-4683 OR TOLL FREE (888) 621-5878  
IF AFTER HOURS OR ON WEEKENDS OR HOLIDAYS CALL THE PSTD EMERGENCY PHONE  
(405) 823-0994**