

## Resources for Compatibility Determination

Beginning October 13, 2015, owners and operators must maintain records that document compatibility of the underground storage tank system (this includes the tank, piping, containment sumps, pumping equipment, release detection equipment, spill equipment and overfill equipment) **if it stores regulated substances containing greater than E10 or B20**. These records must be maintained for as long as the UST system is used to store one of these regulated substances.

Listed below are links to organizations with statements and/or letters of compatibility from UST system manufacturers that you can print off at no charge. A copy of the statement/letter should be kept at the facility for as long as the tank system is used to store these substances. Additionally, a copy should be submitted to PSTD. We will update the list as the information becomes available to us.

Petroleum Equipment Institute:

<http://www.pei.org/ust-component-compatibility-library>

Steel Tank Institute:

<http://www.steeltank.com/Portals/0/Shop%20Fab/SteelAndAlternativeFuels/STI%20Fuel%20Statement.pdf>

<http://www.steeltank.com/Publications/E85BioDieselandAlternativeFuels/ManufacturerStatementsofCompatibility/tabid/468/Default.aspx>

Underwriters Laboratories:

<http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.html>

California State Water Resources Board:

[http://www.waterboards.ca.gov/water\\_issues/programs/ust/alt\\_comp\\_opt/soc.shtml](http://www.waterboards.ca.gov/water_issues/programs/ust/alt_comp_opt/soc.shtml)