

Photo #:

2.72	Is the counter surface of at least one aisle no higher than 38 inches above the floor? [904.3.2]	Yes No Measurement:	38"max	Photo #:	• Lower counter •
2.73	Is the top of the counter edge protection no higher than 2 inches above the counter surface? [904.3.2]	Yes No Measurement:	¢2"max	Photo #:	 Lower edge protection
2.74	If there is a check writing surface, is the top no less than 28 inches and no greater than 34 inches above the floor? [904.3.3]	Yes No Measurement:	28"-34"	Photo #:	 Alter check writing surface
2.75	If there is more than one check- out aisle is there a sign with the International Symbol of Accessibility at the accessible aisle? [216.11]	□ _{Yes} □ _{No}	Ġ.	Photo #:	 Add sign

2.76	Is there a portion of at least one of each type of counter				Lower section of counterLengthen section of
	that is:	□ _{Yes} □ _{No}	36"min		counter •
	No higher than 36 inches above the floor?	Measurement:			
			36"max		
	At least 36 inches long? [904.4.1]	Yes No Measurement:			
		weasurement:		Photo #:	
2.77	Does the accessible portion of the counter extend the same depth as the counter top? [904.4]	Yes No			• Alter accessible portion
		Measurement:			•
	[504.4]				
2.78	Is there a clear floor space at			Photo #:	Reconfigure to provide a
2.70	least 30 inches wide by at least 48 inches long for a forward or parallel approach?	Yes No			parallel or forward
		Parallel			approach •
	[904.4]	Measurement:			•
		Forward			
		Measurement:	48"min		
			30"min Or		
			Ur		

