



Date of Issuance: 12/5/2025

Solicitation No. 3450035914

Requisition No. 26-FM-0017

Amendment No. 2

Hour and date specified for receipt of offers is changed: ☒ No ☐ Yes, to: _____ CST

Pursuant to OAC 260:115-7-30(d), this document shall serve as official notice of amendment to the solicitation identified above. Such notice is being provided to all suppliers to which the original solicitation was sent.

Suppliers submitting bids or quotations shall acknowledge receipt of this solicitation amendment prior to the hour and date specified in the solicitation as follows:

Sign and return a copy of this amendment with the solicitation response being submitted; or,

If the supplier has already submitted a response, this acknowledgement must be signed and returned prior to the solicitation deadline. All amendment acknowledgements submitted separately shall have the solicitation number and bid opening date in the subject line of the email.

ISSUED FROM:

Heather Osborne
Contracting Officer

405-420-2293
Phone Number

hosborne@odot.org
E-Mail Address

RETURN TO: odotbids@odot.ok.gov

Description of Amendment:

a. This is to incorporate the following:

Amendment 2 covers:

Updated Plan-holder's List

Re-revised Pay Item Sheet (Excel)

Questions and Answers that were inadvertently omitted from Amendment 1 have now been included.

Interested Contractors should complete Section b and include this form with their responses.

b. All other terms and conditions remain unchanged.

Supplier Company Name (**PRINT**)

Date

Authorized Representative Name (**PRINT**) Title

Authorized Representative Signature

McClain County Combined Maintenance Yard

Solicitation # 3450035914

Planholder’s List

Company Name	Contact Name	Phone #	Email Address	City/State/Zip	Sent
WL McNatt & Company	Jason Masterson	405-232-7245	Jason@wlmcnatt.com	OKC, OK 73131	x
Cooley Construction	Vickie Guy	405-210-3168	vguy@cooleyconstruction.com	OKC, OK 73111	x
AC Owen Construction	Conner Poss	918-277-0976	Connor@ac-owen.com	Edmond/Tulsa	x
Mid-Plains Construction	Stacy Wilson	580-924-0288	mpc@midplainsinc.com	Durant, OK 74701	x
Clyde Riggs Construction	Garrett Todd	405-990-1831	garrettt@clyderiggs.com	OKC, OK	x
Pillar Contracting	Cole Travis	405-818-3075	ctravis@pillarcontracting.com	OKC, OK 73132	x
Iscani Industries	Stephanie Lidyard	405-348-9300	slidyard@wichita-iscani.com	Edmond, OK 73013	x
Ascend Commercial Builders	Kyle Jackson	918-260-4755	Kyle@ascendok.com	Tulsa, OK 74105	x
Premier Lighting Sales (S)	Jennifer Rozene	918-669-9008	jrozene@plsok.com	Tulsa, OK 74145	X
L5 Construction	Samuel Crabtree	405-226-9861	scrabtree@L5GC.com	OKC, OK 73127	x
TCS Construction	Tony Scorsone	405-503-5046	tony@tcs-ok.com	OKC, OK 73120	x
Lambert Construction Co	Donna Abbott	405-880-7826	Donna@lambertconstructionco.com	Stillwater, OK 74074	x
Thompson General Contracting	Ben Thompson	405-412-7656	ben@thompsongeneralcontracting.net		x
Downey Contracting	David Shaw	405-478-5277	dshaw@downeycontracting.com	OKC, OK 73121	X

McClain County Combined Maintenance Yard

Solicitation # 3450035914

Greystone Construction	Mitchell Lawless	715-660-9753	mlawless@greystoneconstruction.com		x
Midtown Construction	Shawn Carson	405-640-6886	shawn@midtownconst.com	Edmond, OK 73003	x
Shiloh Enterprises	Steve Preston	405-341-5500	steve@shiloh-inc.com	Edmond, OK 73034	X
WP Construction	Brian Patterson	918-693-3258	bpatterson.wpc@gmail.com	Elk City, OK 73644	X
Treas Construction	James Schreiber	405-823-7173	james@treasconstruction.com	Coalgate, OK 74538	X
Hoey Construction	Philip Goddard	918-277-3390	pgoddard@hoeyconstruction.com	Tulsa, OK 74107	x
Stronghold Construction	Kenlee Becknel	405-996-0236	Kenlee@stronghold.construction	OKC, OK 74820	X
MacCo	Matt McConnell	417-499-8450	mmcconnell@maccobuilders.com	Joplin, MO	x
Hope Construction	Heath Ellis	580-467-4862	heath.ellis@gotilley.com		x
Crossland Construction	Paige Melaven	620-429-1414	pmelaven@crossland.com	Columbus, KS	x
Lopp Construction	Wyatt Lopp	405-466-9259	Wyatt@loppconstruction.com	Stillwater, OK	x
Wayne Contracting	Hannah Johnson	572-216-5006	hjohnson@waynecontractingco.com	OKC, OK	X
Thompson Construction	Caleb Lundry	918-764-5446	clundry@tcio.com	Tulsa, OK 74133	X
JNL Construction	Kylie Nelson	405-757-8054	kylie@jnlconstructionllc.com	OKC, OK 73116	X
Landmark Construction Group	Rod Smith	405-843-8041	rsmith@landmarkokc.com	OKC, OK 73114	X
Box Construction	Heather Hendrix	405-837-1757	heatherh@boxconstructionllc.com		x

McClain County Combined Maintenance Yard

Solicitation # 3450035914

Hoidale Inc (S)	Craig Quigley	405-323-5728	cquigley@hoidale.com	OKC, OK 73127	x
All Roads Paving	Will Freeland	580-471-5099	will@allroadspaving.com	OKC, OK 73127	x
Sagemill Construction	Rance Miller	918-810-4071	rance@sagemill.net		X
Triangular Sil Dike Co	Bobby Gibson	513-267-9721	bgibson@tri-siltdike.com		x
Third Generation Electric (S)	April Price	918-504-5394	april@tgetulsa.com	Tulsa, OK	x
Calm Construction	Kayla Stoneking	405-265-7126	Kayla@calmconstruct.com		X

P = Prime Contractor S = Subcontractor

QUESTIONS AND ANSWERS

Q 1: The plans identify storm piping "SD," but the size and material are not identified. Can that be provided?

A 1: Size is identified on sheets CG201 and CG202. An addendum will be issued to show material; all storm piping smaller than 12" diameter is to be HDPE.

Q 2: There is no place on the pay items for the storm sewer and manholes. Only the 140' of 12" RCP and end sections are shown for storm sewer. Please provide a line item for this storm drainage/manholes.

A 2: An updated pay item list will be provided.

Q 3: Are there any drainage structures behind the Hopper Rack? Plans indicate a storm drain line directly behind the Hopper rack, but there is no provision for collecting drainage at this location.

A 3: The hopper racks are equipped with drains for each bay. An addendum will be issued to reflect this correction.

Q 4: The pay item sheet appears to have a couple of errors: Please address.

- Flexamat ditch liner says 7535.44 square yards, but according to our take-offs, it should be closer to 1595 sq yards.
- Select Fill line items does not have a listed quantity.
- Site Storm Sewer line item does not account for the manholes. Where do we provide pricing for manholes?
- Mobilization line item says 4% and Bonds & Insurance says 2%. If the intent is to say that we are limited to charging 4% and 2% respectively, for those two categories, but it would be easier if we could list those two items as a lump sum with the understanding that we can't bill more than 4% for mobilization and 2% for bonds/insurance.
- Sanitary sewer line item says it is 6", but the plans call for 4" sanitary sewer lines.
- There is a pay item for Sod, 7535.44 square yards, but the plans don't call for any sod. There are notes about all disturbed areas being seeded unless otherwise noted. Please clarify where sod is located and where seeding will be required and also provide the pay item for Seeding.
- There are no pay items for the following: generator pad, transformer pad, light pole bases, and CORS Tower.

A 4: **Flexamat ditch liner: quantity should be 1595 SY. An updated pay list will be provided.**
 Select fill: quantity should be 13,380 CY
 Storm sewer manholes: An updated pay item list will be provided.
 Sanitary sewer lines: An updated pay item list will be provided; 4" sanitary lines will be added.
 Sod/Seed: An addendum will be issued that changes all references for seeding to sodding.
 Pad/Bases/CORS Tower: An updated pay item list will be provided that includes these items.

Q 5: There is no erosion control plan or silt fence called out on the plans. Please provide an erosion control plan.

A 5: An addendum will be issued that includes an erosion control plan.

McClain Co Combined Facility
Solicitation 26-FM-0017

Q 6: Are there any additional specifications for the Fuel Tank system beyond the notes on C-503?

A 6: Specifications for the footings, slab, and related requirements fall under the responsibility of the tank manufacturer.

Q 7: Is there a list of approved ODOT fuel system vendors available?

A 7: No

Q 8: Can you provide any manufacturer or more specific information for the fueling system other than the tank capacity and the requirements listed in Notes #1-#3 on C-503?

A 8: Specifications for the footings, slab, and related requirements fall under the responsibility of the tank manufacturer.

Q 9: Can you please provide a geotechnical report for this project?

A 9: Included and attached.

Q 10: Are the building widths hard-set at 42' and 60', or would 40' or 62' also be acceptable if that is the standard width available from our supplier?

A 10: The building widths as shown on the bid documents shall be followed.

Q 11: Is the 12' Truss spacing a hard-set requirement, or are other spacings acceptable as long as they are engineered and have sealed drawings?

A 11: Truss spacing of 12'0" is required.

Q 12: Is a fabric back-end wall needed for either building? Are there any mesh vents or framing for fans?

A 12: Yes, fabric back endwall is required on both buildings and vents to be provided by fabric structure manufacturer, including size and installation requirements.

Q 13: Is a front-end wall needed for either building? Door opening? Fabric Gather Door? Vents?

A 13: No

Q 14: Is the project tax-exempt?

A 14: The State is tax-exempt. That status does not extend to the awarded contractor.

Q 15: What trade are you wanting to pick the drainage ditch with - flex mat, dirt contractor, utilities, or someone else?

McClain Co Combined Facility
Solicitation 26-FM-0017

A 15: Selection of the trade/subcontractor performing drainage ditch work is the choice of the Contractor.