



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 1](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/15/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC-2015

Code Modified: 2018 IFGC

Original Comment Form Number: AFPTC 5

Rule Number: 748:20-12-7 (1) & (2)

Which area of the code (Section, Table, Figure) was revised?

Chapter 2 Definitions

Page Number: 2-1 thru 2-8

Previous Change:

DISPENSING AREA. The appropriate hazardous (classified) locations for the fuel being dispensed in accordance with the National Electrical Code® – NFPA® 70.

MAIN RAILROAD TRACK. That part of the railway, exclusive of switch tracks, branches, yards, and terminals upon which trains are operated by timetable or train order or both.

Historical information

The definition of a "Dispensing Area" was added to clarify multiple references in the IFGC and is not in the 2021 code.

The definition of a "Main railroad track" was added to provide clarity to the code enforcement official and result in more uniform compliance across the state. The definition is not in the 2021 code.