



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 10](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: [OUBCC Staff](#)

Date [5/17/23](#)

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: [405-521-6501](tel:405-521-6501)

Code Change Information

Originating Committee: FGMP 2015

Code Modified: [2018 IMC](#)

Original Comment Form Number: FGMP 41

Rule Number: [748:20-14-8 \(1\)](#)

Which area of the code (Section, Table, Figure) was revised?

[Chapter 3, Section 301.15](#)

Page Number: [3-2](#)

Previous Change:

301.15 Wind resistance. Mechanical equipment, appliances and supports that are exposed to wind shall be designed and installed to resist the wind pressures determined in accordance with the International Building Code®, [SMACNA HVAC Duct Construction Standards - Metal and Flexible](#), and other approved methods.

Historical information

This change was added by the FGMP-2015 committee to add a new standard to the requirements for mechanical equipment, appliances, and supports exposed to wind to be signed and installed to resist.