



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 13](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: [OUBCC Staff](#)

Date [5/17/23](#)

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: [405-521-6501](#)

Code Change Information

Originating Committee: AFPTC 2015

Code Modified: [2018 IMC](#)

Original Comment Form Number: AFPTC 18

Rule Number: [748:20-14-10 \(1\)](#)

Which area of the code (Section, Table, Figure) was revised?

[Chapter 5, Section 502.15](#)

Page Number: [5-8](#)

Previous Change:

502.15 Repair garages. Where Class I liquids or LP-gas are stored or used within a building having a basement or pit wherein flammable vapors could accumulate, the basement or pit shall be provided with ventilation designed in accordance with Section 2311.4.3 of the International Fire Code® to prevent the accumulation of flammable vapors therein.

Historical information

This section was modified by the AFPTC committee to require anyone utilizing the IMC to design ventilation requirements to look at the IFC for requirements for alternative fuels.