



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 16](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2015

Code Modified: 2018 IMC

Original Comment Form Number: FGMP 46

Rule Number: 748:20-14-11

Which area of the code (Section, Table, Figure) was revised?

Chapter 6, Section 604.1

Page Number: 6-6

Previous Change:

604.1 General. Duct insulation shall conform to the requirements of Sections 604.2 through 604.13, the International Energy Conservation Code® and SMACNA HVAC Duct Construction Standards – Metal and Flexible.

Historical information

This modification was originally made in the 2015 adoption. It adds a standard that all duct installation will conform to as it provides the proper methods for tabbing and affixing insulation to ductwork.