



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 19](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2018

Code Modified: 2018 IMC

Original Comment Form Number: SCF 56

Rule Number: 748:20-14-19

Which area of the code (Section, Table, Figure) was revised?

Chapter 14, Section 1402.8.3

Page Number: 14-2

Previous Change:

1402.8.3 Piping. Potable piping shall be installed in accordance with the International Plumbing Code®. Hydronic piping shall be installed in accordance with Chapter ~~10~~ 12 of this code. Mechanical system piping shall be supported in accordance with Section 305.

Historical information

This section was modified by the FGMP 2018 committee to address errata published by ICC. The error has been corrected in the 2021 code. Staff recommendation is to delete the modification from the agency's rules.