



# OKLAHOMA

## Uniform Building Code Commission Staff Comment Form - [FGMP 20](#)

### FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### Contact Information:

Name: [OUBCC Staff](#)

Date [5/17/23](#)

Email: [Kathy.Hehnly@oubcc.ok.gov](mailto:Kathy.Hehnly@oubcc.ok.gov)

Phone: [405-521-6501](tel:405-521-6501)

#### Code Change Information

Originating Committee: FGMP 2015

Code Modified: [2018 IPC](#)

Original Comment Form Number: FGMP 31

Rule Number: [748:20-16-7](#)

#### Which area of the code (Section, Table, Figure) was revised?

[Chapter 2 Definitions](#)

Page Number: [2-2](#)

#### Previous Change:

**BUILDING DRAIN.** That part of the lowest piping of a drainage system that receives the discharge from soil, waste, and other drainage pipes inside and that extends ~~30 inches (752 mm)~~ 5 feet (1524 mm) in developed length of pipe beyond the exterior walls of the building and conveys the drainage to the building sewer.

- (1) Combined. A building drain that conveys both sewage and storm water or other drainage.
- (2) Sanitary. A building drain that conveys sewage only.
- (3) Storm. A building drain that conveys storm water or other drainage, but not sewage.

#### Historical information

This change was made by the 2015 FGMP committee to better align with the industry convention that the site sewer (civil) picks up at 5 feet outside of the building. The 2021 edition lists the same definition as the 2018 without the OUBCC modification.