



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 21](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: [OUBCC Staff](#)

Date [5/17/23](#)

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: [405-521-6501](tel:405-521-6501)

Code Change Information

Originating Committee: FGMP 2015

Code Modified: [2018 IPC](#)

Original Comment Form Number: FGMP 12

Rule Number: [748:20-16-8 \(1\)](#)

Which area of the code (Section, Table, Figure) was revised?

[Chapter 3, Section 305.3](#)

Page Number: [3-2](#)

Previous Change:

305.3 Pipes through foundation walls. Any pipe that passes through a foundation wall shall be provided with a relieving arch or pipe sleeve pipe shall be built into the foundation wall. The relieving arch or pipe sleeve shall conform to one of the materials and standards listed in Table 702.2, or as approved. The sleeve shall be two pipe sizes greater than the pipe passing through the wall.

Historical information

This modification was added by the 2015 committee to clear up confusion about the materials to be used in making relieving arches. The added language is not in the 2021 code.