



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 22](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: [OUBCC Staff](#)

Date [5/17/23](#)

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: [405-521-6501](tel:405-521-6501)

Code Change Information

Originating Committee: FGMP 2015

Code Modified: [2018 IPC](#)

Original Comment Form Number: FGMP 22

Rule Number: [748:20-16-8 \(2\)](#)

Which area of the code (Section, Table, Figure) was revised?

[Chapter 3, Section 305.4.1](#)

Page Number: [3-2](#)

Previous Change:

305.4.1 Sewer depth. Building sewers that connect to private sewage disposal systems shall be ~~installed not less than [NUMBER] inches (mm)~~ a minimum of 12 inches (305 mm) or as approved by the authority having jurisdiction below finished grade at the point of septic tank connection. Building sewers shall be ~~installed not less than [NUMBER] inches (mm)~~ a minimum of 12 inches (305 mm) below grade.

Historical information

This modification was originally made by the 2009 committee then modified by the 2015 committee. The code requires a number to be inserted, but the committee has added language to address another option if approved by the local authority having jurisdiction. The 2021 language matches the published language of the 2018 code.