



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 35](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2018

Code Modified: 2018 IPC

Original Comment Form Number: SCF-51

Rule Number: 748:20-16-11 (5)

Which area of the code (Section, Table, Figure) was revised?

Chapter 6, Section 608.17.7

Page Number: 6-16

Previous Change:

608.17.7 Chemical dispensers. Where chemical dispensers connect to the potable water distribution system, the water supply system shall be protected against backflow in accordance with Section 608.14.1, 608.14.2, 608.14.5, 608.14.6 or 608.14.8 ~~or 608.17.9.~~

Historical information

This change was originally made by the 2018 FGMP committee to address errata published by the ICC. The errata was corrected in the 2021 edition. Staff recommendation is to delete the modification from the agency rules.