



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 37](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2015

Code Modified: 2018 IPC

Original Comment Form Number: FGMP 54

Rule Number: 748:20-16-12 (2)

Which area of the code (Section, Table, Figure) was revised?

Chapter 7, Section 708.1.3

Page Number: 7-7

Previous Change:

708.1.3 Building drain and building sewer junction. The junction of the building drain and the building sewer shall be served by a cleanout that is located at the junction or within ~~10 feet (3048 mm)~~ 12 feet (3658 mm) of the developed length of piping upstream of the junction. For the requirements of this section, the removal of the water closet shall not be required to provide cleanout access.

Historical information

This change was originally made by the 2015 FGMP committee. The submitter noted the cleanout should be located at the junction or within 12 feet. The change does not exist in the 2021 code.